



rfo-sfps-rajkot@gujarat.gov.in



FORM B 13.3
FIRE SAFETY CERTIFICATE RENEWAL (FSCR)
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFORAJ/2024/00065617
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFORAJ/2024/00065617/R1

Date: 08/07/2024

Building Occupancy/Category: Educational (non-residential)

To,

Mrs Malathi Naidu
- MATHAK ANJAR ANJAR Kachchh 370110
Fire Region: Rajkot RFO
Mobile No: 7351535158 Email ID: info@eklavyavidyamandir.com

This has reference to your Application No. 2024/00065873 dated 12/06/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise EKLAVYA VIDHYAMANDIR (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number: S.R. NO. 144/144-PAIKI 02,
4. Village Name: ANJAR
5. Name of Block(s): EKLAVYA VIDYAMANDIR

The building/premise was inspected on 08/07/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 08/07/2024
2. Six monthly inspection was done on 08/07/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 08/07/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

Malathi

Principal
Eklavya Vidyamandir
Survey No. 144/144-2,

Mathak, Anjar, Kutch 370410



Digitally Verified

Digitally verified by: Dipen Rajendrabhai Hansora
Fire Safety Officer - General (FSO-G)
2021/001355

Date: 08/07/2024
Time: 11:59 AM

Dipen Hansora
For Eklavya Vidyamandir
Authorised Signatory

FSCA/O/RFORAJ/2024/00065617/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.